

**Lead Testing Program
Statement of Assurance
(Non-Lead Testing Year)**

County: Burlington

School District, Charter School, Renaissance school project, jointure commission, or other eligible organization as defined in N.J.A.C. 6A:26A-1:

Beverly City

Address: 601 Bently ave, Beverly, NJ 08010

Chief School Administrator (CSA): Elizabeth Giacobbe

Telephone #: 609-387-2200

CSA Email: egiacobbe@beverlycityschool.org

Alternate Contact Person: George Gahles

Telephone #: 609-387-2200

Title: Business Administrator

Email: ggahles@beverlycityschool.org

1. The school district, charter school, renaissance school, jointure commission, educational services commission, approved private school for students with disabilities acting under contract to provide educational services on behalf of New Jersey public school districts, state-funded early childcare facilities pursuant to N.J.A.C. 6A:13A, and receiving schools as defined by N.J.A.C. 6A:14-7.1(a) (hereinafter collectively referred to as "District"), has reviewed N.J.A.C 6A:26 requiring testing for lead in drinking water and has provided assurance that lead testing has been completed within six (6) years in accordance with the technical guidelines established by the NJ Department of Environmental Protection. Additionally, all notifications of test results have been provided consistent with this subchapter, including the requirement to make the test results publicly available on the District's website, and alternate drinking water continues to be made available to all students and staff.
2. The date of the most recent lead testing conducted in accordance with the technical guidelines established by the NJ Department of Environment Protection was: 4/27/16.
3. The District will continue to fully implement the N.J.A.C. 6A:26-12.4 regulations.
4. The District will maintain compliance with all applicable laws, codes, and regulations governing the provision of potable drinking water and testing of drinking water for lead including, but not limited to, N.J.A.C. 6A:26-12.4; the Safe Drinking Water Act, N.J.S.A. 58:12A-1 et seq., and the rules promulgated pursuant thereto, N.J.A.C. 7:10 and N.J.A.C. 6A:26-6, Planning and Construction Standards for School Facilities.

Certification:

By signing below, the Chief School Administrator certifies that all statements above are true and correct:

Name: George Gahles

Title: Business administrator

Signature: 

Date: 6/30/19

J.R. HENDERSON LABS, INC.
 123 SEAMAN AVENUE
 BEACHWOOD, NJ 08722-2817
 Certified Lab. I.D #15083

WATER SYSTEM NAME: BEVERLY CITY SCHOOL –
 601 BENTLY AVENUE
 BEVERLY, NJ 08010

SAMPLE DATE: 4/27/16 4 Non-Compliance Samples PARAMETER: LEAD

Testing Site: BEVERLY CITY SCHOOL- CONTACT-BRIAN-732-684-2864

LOCATION	SAMPLE DATE/TIME	ANALYTE NAME	ANALYTICAL METHOD	ANALYSIS DATE/TIME	RESULTS MG/L
1.Fountain-Teacher Lounge	4/27/16 07:00	LEAD	200.9	5/12/16 10:06	0.002
B Business Office Kitchen Sink	4/27/16 07:00	LEAD	200.9	5/12/16 10:28	<0.001
C Sink Outside Office	4/27/16 07:00	LEAD	200.9	5/12/16 10:32	<0.001
D Kitchen Sink	4/27/16 07:00	LEAD	200.9	5/12/16 10:36	0.002

MG/L=Milligrams of contaminant per liter of water equivalent to ppm (parts per million)

Sampled and analyzed as per EPA Testing Schools and Child Care Center for Lead in Drinking Water. (Action Level for Lead is 0.015 mg/l)